

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

McElroy Metal, Inc. 1500 Hamilton Road Bossier City, LA 71111

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER- Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: "PBR Panel Wall" .023"(min) Steel Wall Panel

APPROVAL DOCUMENT: Drawing No. E, titled "PBR – Panel Waterhead Test", sheets 1 through 5 of 5, prepared by McElroy Metal, Inc. Engineering Services Dept., signed and sealed by Terrence E. Wolfe, P.E. on February 12, 2009, bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and the expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each panel shall bear a permanent label with the manufacturer's name or logo:

1500 Hamilton Road 9700 Interstate 20 253 One Georgia Dr. 460 Clay Road 10490 State Hwy 10 Bossier City, LA 71111 Merkel, TX 79536 Ashburn, GA 31714 Sunnyvale, TX 75182 Clinton, ILL 61727 and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA # 09-0504.08 and consists of this page 1, evidence submitted pages E-1 & E-2 and approval document mentioned above.

The submitted documentation was reviewed by Helmy A. Makar, P.E., M.S.

MIAMI-DADE COUNTY
APPROVED

He G. A. Meh 01/16/2014 NOA No. 14-0102.07 Expiration Date: 03/18/2019 Approval Date: 01/16/2014 Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUA APPROVAL # 08-1007.07

A. DRAWINGS

1. Drawing No. E, titled "PBR—Panel Waterhead Test", sheets 1 through 5 of 5, prepared by McElroy Metal, Inc. Engineering Services Dept., signed and sealed by Terrence E. Wolfe, P.E. on February 12,2009.

B. TESTS

- 1. Test reports on:
 - 1) Air Infiltration Test, per FBC, TAS 202-94
 - 2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
 - 3) Water Resistance Test, per FBC, TAS 202-94
 - 4) Large Missile Impact Test, per FBC, TAS 201-94
 - 5) Cyclic Wind Pressure Loading, per FBC, TAS 203-94 along with drawings and installation diagram of PBR Panel assembly, prepared by Farabaugh Engineering and Testing, Test Report No. T295-07, dated 09/30/07, (revised 4/23/08) signed and sealed by Daniel G. Farabaugh, P.E.

C. CALCULATIONS

1. Calculations titled "R Panel, 24 Ga.", 2 pages, prepared by Terrence E. Wolfe, P.E., signed and sealed by Terrence E. Wolfe, P.E. on December 6, 2008.

D. QUALITY ASSURANCE

1. By Miami-Dade County Building Code Compliance Office.

E. MATERIAL CERTIFICATIONS

1. Tensile Test, prepared by West Penn Material Evaluation, dated September 12, 2007.

2. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 09-0504.08

A. DRAWINGS

1. None.

B. TESTS

1. None.

C. CALCULATIONS

1. None.

D. QUALITY ASSURANCE

1. By Miami-Dade County Building Code Compliance Office.

E. MATERIAL CERTIFICATIONS

1. None.

Helmy A. Makar, P.E., M.S. Product Control Unit Supervisor NOA No. 14-0102.07

Expiration Date: 03/18/2019 Approval Date: 01/16/2014

McElroy Metal, Inc.


NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED


- 3. NEW EVIDENCE SUBMITTED
- A. DRAWINGS
 - 1. None.
- B. TESTS
 - 1. None.
- C. CALCULATIONS
 - 1. None.
- D. QUALITY ASSURANCE
 - 1. By Miami-Dade County Department of Regulatory and Economic Resources.
- E. MATERIAL CERTIFICATIONS
 - 1. None.
- F. STATEMENTS
 - 1. FBC, 2010 Edition compliance letter issued by Force Engineering & Testing, Inc., dated November 22, 2013, signed and sealed by Terrence E. Wolfe, P.E.


Hélmy A. Makar, P.E., M.S. Product Control Unit Supervisor


> NOA No. 14-0102.07 Expiration Date: 03/18/2019


Approval Date: 01/16/2014











- NOIES:

 1. THE MAXIMUM UPLIFT DESIGN PRESSURE SHALL BE CALCULATED USING THE FOLLOWING ALLOWABLES.

 A) MAXIMUM ALLOWABLE BENDING MOMENT OF THE PANEL AT SUPPORTS = 156.25 FL LB.
 - B) MAXIMUM ALLOWASIE BENOING MOMENT OF THE PANEL BETWEEN SUPPORTS 87.89 FT. 18.
 - C) MAXIMUM ALLOWABLE DEFLECTION OF WALL PANEL = L/240
 - D) MAXIMUM SUPPORT REACTION = 93,75 LBS, EXT.
 - 156.25 LBS. INT. E) El = 1.2213 X 10 18-142

2. THE MAXIMUM ALLOWABLE SPANS & PRESSURES ARE AS FOLLOWS:

SPAN 5'~0" PRESSURE 50.0 PSF

36" ±1/16" COVERAGE 12"

PBR-PANEL

PRODUCT REVISED as complying with the Florida Building Code

Acceptance No 9-Expiration Date 03/18/2

Miami Dado Product Control Division

Approved as complying with the Plufda Building Code
Date 2:23:09
NOA# 08-1007-07
Miami Dade Product Control
Divides Division Harris

PRODUCT RENEWED as complying with the Florida Building Code Acceptance No /4 Expiration Date 03

Miami Dade Boduct Control

SKUTLEX 201 URETHUNE TUBE SEALANT BY: SKA

— 1/8" X 1" BUTYL ROLL TUPE SEALANT BY: SCHNEE-WORDIELD

SKALASTONER 511 TUBE SEALANT BY: SKA

PANEL ACCESSORIES

1/4-14 X 7/8" LAP/TEK BI: SPS NTEC

#12-14 X 1 1/4" HMH TEX2

PANEL PROPERTIES PANEL PANEL YEILD **TENSILE** STEEL **PAINT** ASTM GAUGE **THICKNESS** STRENGTH **STRENGTH** COATING COATINGS A792 24 .023 (MIN.) AZ 55 (BARE) 50 KSI (MIN.) KYNAR 500 65 KSI (MIN.) AZ 50 (PAINTED)

FOR CONSTRUCTION

INC McELROY

DADE COUNTY TESTING PBR-PANEL WATERHEAD TEST MGELROY METAL, INC. MAN'F. ENG.: TERRENCE E. WOLFE, P. FL REGISTRATION #, 44923

SCALE: N.T.S. PATE: 8/11/07

DWN, BY: J. PURDY CHKO BY: E. OSTE

OG NO: E5 of 5 Dec to the Principle of the Principle of